

## **Chilton Parish Council**

The Minutes of the Meeting of Chilton Planning Committee held on Monday 8<sup>th</sup> August at 8.00pm in the Village Hall

Present	Mr C Broad	Chairman
	Mrs L Amstead	
	Mr R Girling	
	Dr M Hansard	

1. Apologies for Absence were received from Dr Druce and Dr Berry.
2. Declarations of Interest
3. Open Forum
4. Application for installation of an air source heat pump to the NE elevation of the property 43 Limetrees P2/V1648/HH

Comments

Chilton Parish Council does not object to the installation of the heat pump but objects to the position as it is very prominent on the street scene. The Council believes that it contravenes the latest South & Vale Joint Design Guide. The noise levels should be mitigated and not exceed 45dB as stated in the Environmental Protection comment.

The Chairman closed the Meeting at 8.15pm