

**Legionella Risk Assessment**  
**Parson Lathams Hospital in Barnwell**

Hazard	Who affected	Control Measures
Water Tanks	Residents Trustees Visitors Contractors Employees	Inspection of Tanks carried out by competent contractor. Cleaning of tanks to be carried out if necessary. Repeat at same time as Quinquennial Inspection or more often if necessary.
Taps	Residents Trustees Visitors Contractors Employees	Periodic measuring of the temperature of one hot and one cold tap in each property – different taps to be tested each time, to ensure temperature within safe limits to inhibit growth of legionella.
Shower	Residents Trustees Visitors Contractors Employees	If property empty for prolonged period of time shower head and hose removed and replaced with a new one.  If property empty for a short period shower to be turned on and water washed through at regular intervals

Signed:

Chairman

Date:

To be reviewed annually